

Water Treatment Service and Maintenance

Option A – Water Treatment Quick Check \$345.00

- Water quality test for iron, PH, manganese, and hardness.
- Check for correct settings on water treatment heads.
- Check for motor operation.
- Check for leaks.
- Check for pistons to be freely turning.
- Run backwash cycle and check for correct operation.

Option B – Control Valve Rebuild \$286.00/Head

- Put water treatment head into bypass.
- Remove head and disassemble.
- Install new seals, spacers, and piston (parts included).
- Lubricate all moving parts with manufacturer approved lubricant.
- “Top off” calcite if applicable (cost of calcite not included).
- Reassemble heads and put the head back into service.
- Put the system into backwash and check for correct operation.
- Must be in conjunction with Option A.

Option C – Re-bed Media Tanks \$731.00/Tank

- Test water quality before and after water treatment plant to confirm effectiveness.
- Put system into bypass.
- Remove control valve head.
- Remove tank from the residence or building.
- Wash and rinse out tanks.
- Re-bed with new media (gravel and Smart-Blend, media included for a 1.5 cu. ft. tank, larger tanks may have additional media charges)
- Reassemble tank and head.
- Put system back into operation.
- Place system into backwash.
- Retest for water quality.
- Confirm setting and correct operation of the system.
- Must be in conjunction with Option A and Option B